

There's always a solution in steel.

AISC Live Webinars

Thank you for joining our live webinar today.
We will begin shortly. Please stand by.

Thank you.

Need Help?

Call ReadyTalk Support: 800.843.9166



AISC Live Webinars

Today's audio will be broadcast through the internet.

Alternatively, to hear the audio through the phone, dial:

(800) 289-0459

Passcode: 664417



AISC Live Webinars

Today's live webinar will begin shortly. Please stand by.

As a reminder, all lines have been muted. Please type any questions or comments through the Chat feature on the left portion of your screen.

Today's audio will be broadcast through the internet.
Alternatively, to hear the audio through the phone, dial:

(800) 289-0459

Passcode: 664417



AISC Live Webinars

AISC is a Registered Provider with The American Institute of Architects Continuing Education Systems (AIA/CES). Credit(s) earned on completion of this program will be reported to AIA/CES for AIA members. Certificates of Completion for both AIA members and non-AIA members are available upon request.

This program is registered with AIA/CES for continuing professional education. As such, it does not include content that may be deemed or construed to be an approval or endorsement by the AIA of any material of construction or any method or manner of handling, using, distributing, or dealing in any material or product.

Questions related to specific materials, methods, and services will be addressed at the conclusion of this presentation.



AISC Live Webinars

Copyright Materials

This presentation is protected by US and International Copyright laws. Reproduction, distribution, display and use of the presentation without written permission of AISC is prohibited.

© The American Institute of Steel Construction 2018

The information presented herein is based on recognized engineering principles and is for general information only. While it is believed to be accurate, this information should not be applied to any specific application without competent professional examination and verification by a licensed professional engineer. Anyone making use of this information assumes all liability arising from such use.



Course Description

Steel Framed Stairway Design

Part 1: Overview & Gravity Loading

May 30, 2018

This session provides guidance for the design and layout of steel elements for steel framed stairways, guards, handrail and related components. Information regarding stairways, code requirements for gravity loading and serviceability criteria, design methods, and design examples will be presented.



Learning Objectives

- Name the various components of steel framed stairs.
- List the types of stair classes and their characteristics.
- Identify the critical code provisions for creating a stair layout.
- Explain the structural code requirements for gravity load design of stairs for both strength and serviceability.



Steel Framed Stairway Design

There's always a solution in steel.



Presented by
Adam Friedman
CSD Structural Engineers
Milwaukee, WI




Introduction

AISC Design Guide 34: Steel Framed Stairway Design

to be published late summer / fall

will be available at
www.aisc.org/designguides
free download for members or
available for purchase



Outline – Part 1

Step 1 – Purpose & Design Philosophy

Step 2 – Stairway Overview

Step 3 – Code Requirements - Gravity

Step 4 – Stairway Design

Step 5 – Members & Connx

Step 6 – Examples



Outline – Part 2

Step 7 – Code Requirements – Seismic Loading

Step 8 – Seismic Serviceability

Step 9 – Stairway Design

Step 10 – Examples

Step 11 – Delegated Design

Step 12 – Other Topics



11

Outline – Part 1

Step 1 – Purpose & Design Philosophy

Step 2 – Stairway Overview

Step 3 – Code Requirements - Gravity

Step 4 – Stairway Design

Step 5 – Members & Connx

Step 6 – Examples



12



Purpose for Design Guide

- Improve communication & coordination
 - Resolve common issues:
 - Inadequate or incorrect stairway dimensions
 - Unclear code criteria for project
 - Insufficient information in design documents
 - Coordination of support locations
 - Contractual concerns / delegated design
-



13

Design Philosophy

- Follow code & NAAMM *Stair Manual & Railing Manual*:
 - General Stair & Rail Layout
 - Construction Details (various materials)
 - Design Criteria may be out of date
 - For steel stairs, the new Design Guide provides specific layout, details, design methods, and recommendations related to stairways, handrails, and guards fabricated from steel.
 - Provides the most up-to-date guidance for steel stair design
-



14



Design Philosophy

- AISC *Code of Standard Practice (COSP)* defines stairs and handrail as “other items”, therefore these items are outside the scope of the COSP since it is not considered structural steel.
 - But, for steel stairway design, use AISC documents as “reference standards” instead:
 - AISC 2016 *Code of Standard Practice (COSP)*
 - AISC *Steel Construction Manual, 15th Ed. (Manual)*
 - AISC 2016 *Specification for Structural Steel Buildings (Specification)*
-



15

Design Philosophy

- Use AISC documents in conjunction with design documents for steel stair design but confirm with:
 - Architect of Record (AOR)
 - Structural Engineer of Record (SER)
 - Authority Having Jurisdiction (AHJ)
 - General Contractor (GC)
-



16



Outline – Part 1

Step 1 – Purpose & Design Philosophy

Step 2 – Stairway Overview

Step 3 – Code Requirements - Gravity

Step 4 – Stairway Design



Step 5 – Members & Connx

Step 6 – Examples





Stair Types (NAAMM)

- Straight
 - **Straight**
 - Parallel (Switchback)
 - Angled
 - Scissor








Stair Types

- Straight
 - Straight
 - **Parallel (Switchback)**
 - Angled
 - Scissor




Stair Types

- Straight
 - Straight
 - Parallel (Switchback)
 - **Angled**
 - Scissor



Stair Types



- Straight
 - Straight
 - Parallel (Switchback)
 - Angled
 - **Scissor**



21

Stair Types

- Circular
- Curved




22




Stair Types

- Alternating Tread Device



- Ships Ladder



Stair Class (NAAMM)

- **Industrial**
 - functional
 - economical
 - industrial setting
- Service
- Commercial
- Architectural



Stair Class - Industrial



25

Stair Class - Industrial



26




Stair Class - Industrial



27


Stair Class

- Industrial
- **Service**
 - functional
 - “back of house”
 - common egress stair
- Commercial
- Architectural



28

Stair Class - Service



29

Stair Class

- Industrial
- Service
- **Commercial**
 - public use
 - more attractive
- Architectural



30


Stair Class - Commercial



31

Stair Class

- Industrial
- Service
- Commercial
- **Architectural**
 - elaborate
 - custom
 - most expensive



32





Stair Class - Architectural




Stairway Elements

- Tread
- Riser
- Stringer
- Landing
- Handrail
- Guard
- Supports
- Connections



Stairway Elements


- **Tread**
- Riser
- Stringer
- Landing
- Handrail
- Guard
- Supports
- Connections



35

Stairway Elements

- Tread
- **Riser**
- Stringer
- Landing
- Handrail
- Guard
- Supports
- Connections




36




Stairway Elements

- Typical Tread / Riser Ass



“IBC” / Commercial





“OSHA” / Industrial




Stairway Elements

- Tread
- Riser
- **Stringer**
- Landing
- Handrail
- Guard
- Supports
- Connections



Stairway Elements


- Tread
- Riser
- Stringer
- **Landing**
- Handrail
- Guard
- Supports
- Connections



39

Stairway Elements

- Tread
- Riser
- Stringer
- Landing
- **Handrail**
- Guard
- Supports
- Connections




40



Stairway Elements


- Tread
- Riser
- Stringer
- Landing
- Handrail
- **Guard / "Stair Rail System"**
- Supports
- Connections



Stairway Elements

Guard


- Post
- Top Rail
- Low Rail
- Infill
- Toe Kick / Toeboard



Stairway Elements

Guard


- Post
- Top Rail
- **Low Rail**
- Infill
- Toe Kick / Toeboard



Stairway Elements

Guard


- Post
- Top Rail
- Low Rail
- **Infill**
- Toe Kick / Toeboard



Stairway Elements


Guard

- Post
- Top Rail
- Low Rail
- Infill
- **Toe Kick / Toeboard**




Stairway Elements

- Tread
- Riser
- Stringer
- Landing
- Handrail
- Guard
- **Supports**
- Connections



Stairway Elements

- Tread
- Riser
- Stringer
- Landing
- Handrail
- Guard
- Supports
- **Connections**



Stairway Layout – IBC or OSHA?

- Per International Code Council
 - All stairs should follow IBC unless AHJ approves
 - All stairs are egress stairs (even if area served is “unoccupied” or seldom used)
 - Certain exceptions for equipment per International Mechanical Code




Stairway Layout – IBC or OSHA?


IBC stair is OSHA compliant but...
OSHA stair may not be IBC compliant




Stairway Layout - IBC




Stairway Layout – IBC: Riser Height




Stairway Layout – IBC: Egress Width




Stairway Layout – IBC: Egress Width



Stairway Layout – IBC: Guard



Stairway Layout – OSHA




Stairway Layout – OSHA: Updates

- OSHA revised standard 1910 Subpart D as of 1/17/2017
- Renumbered and reorganized:
 - 1910.25 – Stairways
 - 1910.28 – Duty to have fall protection & falling object protection
 - 1910.29 – Fall protection systems and falling object protection-criteria and practices
- Changed riser/tread limits
- Changed vertical clearance
- **Revised guard height and handrail requirements**




Stairway Layout – OSHA: Guard



Stairway Layout – OSHA: Width

- 1910.25(c)(4)
 - Minimum width = 22" between *vertical barriers*
- 1910.25 Figure D-8
 - Minimum *tread* width = 22"
- 1910.36(g)(2)
 - Minimum width = 28" at *all points* for exit routes



MINIMUM TREAD WIDTH 22 IN (56 CM)
MINIMUM TREAD DEPTH 9.5 IN (24 CM)
MAXIMUM RISER HEIGHT 9.5 IN (24 CM)
 OSHA Figure D-8



Stairway Layout – OSHA: Width

- 1910.28(b)(11)(ii) & Table

Each flight of stairs having at least 3 treads and at least 4 risers is equipped with stair rail systems and handrails as follows:

Table D-2 -- Stairway Handrail Requirements

Stair width	Enclosed	One open side	Two open sides	With earth built up on both sides
Less than 44 inches (1.1 m).	At least one handrail	One stair rail system with handrail on open side.	One stair rail system each open side.	
44 inches (1.1 m) to 88 inches (2.2 m).	One handrail on each enclosed side	One Stair rail system with handrail on open side and one handrail on enclosed side.	One stair rail system with handrail on each open side.	
Greater than 88 inches (2.2 m).	One handrail on each enclosed side and one intermediate handrail located in the middle of the stair	One stair rail system with handrail on open side, one handrail on enclosed side, and one intermediate handrail located in the middle of the stair.	One stair rail system with handrail on each open side and one intermediate handrail located in the middle of the stair.	
Exterior stairs less than 44 inches (1.1 m).				One handrail on least one side.

Note to table: The width of the stair must be clear of all obstructions except handrails.



Stairway Layout – OSHA: Width

- 1910.28(b)(11)(ii) & Table

Each flight of stairs having at least 3 treads and at least 4 risers is equipped with stair rail systems and handrails as follows:

Table D-2 -- Stairway Handrail Requirements


Stair width	Enclosed	One open side	Two open sides	With earth built up on both sides
Less than 44 inches (1.1 m).	At least one handrail	One stair rail system with handrail on open side.	One stair rail system each open side.	
44 inches (1.1 m) to 88 inches (2.2 m).	One handrail on each enclosed side	One Stair rail system with handrail on open side and one handrail on enclosed side.	One stair rail system with handrail on each open side.	
Greater than 88 inches (2.2 m).	One handrail on each enclosed side and one intermediate handrail located in the middle of the stair	One stair rail system with handrail on open side, one handrail on enclosed side, and one intermediate handrail located in the middle of the stair.	One stair rail system with handrail on each open side and one intermediate handrail located in the middle of the stair.	
Exterior stairs less than 44 inches (1.1 m).				One handrail on least one side.

Note to table: The width of the stair must be clear of all obstructions except handrails.


Note to table: The width of the stair must be clear of all obstructions except handrails.




Stairway Opening Size



Stairway Opening Size




Stairway Opening Size



Stairway Opening Size

- Field installed slab edge angle
 - Allows for adjustment in field to help with fit-up



* - Coordinate final opening dimensions with Architect & SER during detailing.



Outline – Part 1

Step 1 – Purpose & Design Philosophy

Step 2 – Stairway Overview

Step 3 – Code Requirements - Gravity

Step 4 – Stairway Design

Step 5 – Members & Connx

Step 6 – Examples



69

Applicable Codes

- International Building Code (IBC)
 - Chapter 10 “Means of Egress”
 - Chapter 16 “Structural Design” – Loads, Combos, & Serviceability
- ASCE/SEI 7-16 Minimum Design Loads for Buildings & Other Structures
 - Loading & Load Combinations
- Occupational Safety & Health Administration (OSHA)
 - 1910 Subpart D
 - 1910.25 Stairways
 - 1910.28 Duty to have fall protection and falling object protection
 - 1910.29 Fall protection systems and falling object protection
 - 1910.36 Design and construction requirements for exit routes



70



Load Combinations

- Refer to ASCE7-16 Chapter 2 for LRFD & ASD Load Combinations

LRFD

- 1.4D
- 1.2D+1.6L+0.5(L_r or S or R)
- 1.2D+1.6(L_r or S or R)+1.0(L or 0.5W)
- 1.2D+1.0W+1.0L+0.5(L_r or S or R)
- 0.9D+1.0W
- 1.2D+1.0E_v+1.0E_h+1.0L+0.2S
- 0.9D-1.0E_v+1.0E_h

ASD

- D
- D+L
- D+(L_r or S or R)
- D+0.75L+0.75(L_r or S or R)
- D+0.6W
- D+0.75L+0.75(0.6W)+0.75(L_r or S or R)
- 0.6D+0.6W
- D+0.7E_v+0.7E_h
- D+0.525E_v+0.525E_h+0.75L+0.75S
- 0.6D-0.7E_v+0.7E_h



Loading

- Dead Loads
 - Self weight (steel members, concrete fill, etc.)
 - MEP Allowances
 - Architectural finishes (flooring, walls, soffits, etc.)
 - Typical material weights found in
 - ASCE 7-16 commentary Chapter C3 “Dead Loads”
 - AISC Tables 17-12 & 17-13



Loading – IBC 2015 / ASCE 7-16

- Live Loads

Component	Loading
Stair Tread	300 lb concentrated load on 4 in ² or 100 psf uniform load
Stair Landing	100 psf uniform load
Guard – Top Rail	200 lb force in any direction or 50 lb/foot in any direction
Guard – Infill & Other Rails	50 lb over 1 square foot
Handrail	200 lb force in any direction or 50 lb/foot in any direction



73

Loading – OSHA

Component	Loading
Stair Tread / Landing	Five times “normal live load” or 1,000 lb concentrated load
Guard/Stair Rail System – Top Rail	200 lb force in downward or outward direction
Guard/Stair Rail System – Infill	150 lb force in downward or outward direction
Handrail	200 lb force in downward or outward direction
Toeboard / Toeplate	50 lb force in downward or outward direction



74



Loading – OSHA

- What is “normal live load”?
 - Based on actual usage of the stair
 - Divide total weight of users over stair plan area
 - $300 \text{ lbs} / 20 \text{ ft}^2 = 15 \text{ psf}$
 - Multiply above value by five
 - $15 \text{ psf} \times 5 = 75 \text{ psf} \rightarrow$ “normal live load”
- Recommend using 60 psf minimum design value based on ASCE 7 Table 4-1 for “walkways and elevated platforms”
- 1,000 lb concentrated force may govern



Serviceability – IBC 2015, Table 1604.3

Deflection

Component	L	D+L
Floor members (stringers/landings)	Span/360	Span/240
Supporting tile/brittle floor finish	<i>Span/600</i>	Span/240
Cantilever Guard Post*	Height/60	
Guard, Handrail, Infill**	Span/120	

* - Matches deflection limit for interior partitions with flexible finishes and twice the height for cantilever members

** - Matches deflection limit for interior partitions with flexible finishes



Outline – Part 1

Step 1 – Purpose & Design Philosophy

Step 2 – Stairway Overview

Step 3 – Code Requirements - Gravity

Step 4 – Stairway Design


Step 5 – Members & Connx

Step 6 – Examples



Stairway Design

- Sloping Beam versus Horizontal Plane Method




Sloping beam method

Horizontal plane method



Stairway Design

- Simple Span versus Frame Analysis




Simple span beam analysis

Frame analysis

Stairway Design

- Simple Span



- Roller support allows for some lateral movement. This is a relatively small value for Δ_h on most stairs.
- Designers can accommodate with connections, flexible supports, drift detail.

$$R = V = \frac{wl}{2}$$

$$M_{\max} = \frac{wl^2}{8}$$

$$\Delta_{\max} = \frac{5wl^4}{384EI}$$




Simple span beam analysis



Stairway Design

- Frame Analysis



- Pin supports at each end restrain lateral deflection. Results in very small vertical deflection and large axial reactions due to catenary action or arching action.
- Designers must design connections for large axial reactions.



Frame analysis

Stairway Design – Unbraced Length

- Refer to AISC *Specification* Appendix Section 6.3
 - Determine if tread/riser has adequate stiffness and strength to brace stringer
- Likely fully braced using:
 - Welded tread/riser “Z shape” pans (concrete filled)
 - Welded checker plate
- Needs more research:
 - Bolted grating treads
 - Flat pans (tread only, no riser)
 - Precast, fiberglass, or other manufactured products



Stairway Design – Serviceability

- Deflection Limits
 - IBC Limits
 - 1/4" maximum?
 - Floor/wall finishes
- Vibration Concerns



83

Outline – Part 1

Step 1 – Purpose & Design Philosophy

Step 2 – Stairway Overview

Step 3 – Code Requirements - Gravity

Step 4 – Stairway Design

Step 5 – Members & Connx

Step 6 – Examples




84



Member Selection


- Stringers – Channel, Plate, Rectangular HSS, WF



85

Member Selection

- Guards/Rails – Pipe, HSS, Bar, Rounds, Custom



86



Member Selection


- Guards/Rails – Pipe, HSS, Bar, Rounds, Custom



87

Treads/Risers

- Integral Pan Tread & Riser with Concrete Fill
 - Directly welded
 - Carrier bar or angle for support
 - Refer to AISI code for design of light gauge material
 - Use effective section properties
 - Consider which portion of profile provides strength and stiffness (partially effective)



88

Treads/Risers


- Steel Plate
 - Checkered Plate or Diamond Plate
 - AISC Manual Table 3-18a provides recommended maximum uniform load based on span for a deflection limit of $L/100$
 - AISC Manual Table 3-18b provides recommended maximum uniform load based on span and stress limit of 24 ksi in LRFD and 16 ksi in ASD.
 - Based on ASTM A786 Standard Specification for Steel Floor Plates typically used for checkered/diamond plate applications.
 - Verify section properties and material properties with supplier.
 - Flat plate or stiffened plate



89

Treads/Risers

- Steel Grating
 - Good for wet environments, outdoors, industrial
 - Typically a purchased “buy out” item
 - Confirm with manufacturer for strength & serviceability
 - Verify if ADA requirements must be met (opening sizes in grating)
- Non-steel Options
 - Precast concrete, glass, plastic, wood, fiberglass.
 - Consider if special deflection criteria should be used



90

Stringer

Stringer Type	Advantages	Disadvantages
Channel (C or MC)	<ul style="list-style-type: none"> Variety of sizes, weights, and depths that are widely available Flange can be used to support guard posts End connections can use typical bolted simple shear connections 	<ul style="list-style-type: none"> Wider than plate and some HSS members
Plate	<ul style="list-style-type: none"> Readily available Narrower than other alternatives End connections can use typical bolted simple shear connections 	<ul style="list-style-type: none"> Lower flexural strength than other options compared to member weight Lower member strength for lateral loading
Rectangular HSS	<ul style="list-style-type: none"> Variety of sizes, weights, and depths that are widely available Flange can be used to support guardrail posts 	<ul style="list-style-type: none"> Additional fabrication required at joints and connections More difficult end connections than other options Typically heavier weight per foot than other options



Landings

- Cast-in-place concrete over metal deck
- Cast-in-place concrete over metal plate or stiffened metal plate
- Checkered plate flooring
- Steel grating
- Precast concrete




Landings

- Support Conditions
 - Building Supports
 - Post Supported Landing
 - Hanger Supported Landing
 - Integrated Landing
 - Separate Stair Flights



Landings

- Support Conditions
 - Building Supports
 - **Post Supported Landing**
 - Hanger Supported Landing
 - Integrated Landing
 - Separate Stair Flights




Landings

- Support Conditions
 - Building Supports
 - **Post Supported Landing**
 - Hanger Supported Landing
 - Integrated Landing
 - Separate Stair Flights



Landings

- Support Conditions
 - Building Supports
 - Post Supported Landing
 - **Hanger Supported Landing**
 - Integrated Landing
 - Separate Stair Flights



Landings


- Support Conditions
 - Building Supports
 - Post Supported Landing
 - **Hanger Supported Landing**
 - Integrated Landing
 - Separate Stair Flights



97

Landings

- Support Conditions
 - Building Supports
 - Post Supported Landing
 - Hanger Supported Landing
 - **Integrated Landing**
 - Separate Stair Flights




98




Landings

- Support Conditions
 - Building Supports
 - Post Supported Landing
 - Hanger Supported Landing
 - **Integrated Landing**
 - Separate Stair Flights




Landings

- Support Conditions
 - Building Supports
 - Post Supported Landing
 - Hanger Supported Landing
 - Integrated Landing
 - **Separate Stair Flights**



Landings


- Support Conditions
 - Building Supports
 - Post Supported Landing
 - Hanger Supported Landing
 - Integrated Landing
 - **Separate Stair Flights**



101

Guard & Handrail

- Member Types
 - Pipe
 - HSS Round
 - Rectangular HSS
 - Angle
 - Plate, Bar, & Rod




102




Guard & Handrail

- Member Types
 - **Pipe**
 - HSS Round
 - Rectangular HSS
 - Angle
 - Plate, Bar, & Rod



ASTM A53 GR B
PIPE 1 1/4"




ASTM A53 GR B
PIPE 1 1/2"




Connections

- General
 - AISC Manual Part 7 Bolts
 - AISC Manual Part 8 Welds
 - AISC Manual Part 9 Connecting Elements
 - AISC Specification
 - AISC Design Examples (available at aisc.org)
 - DG24 – Hollow Structural Section Connections
- Shear
 - AISC Manual Part 10




Connections

- Shear & Axial
 - Follow AISC *Specification & Design Examples* (available at aisc.org)
- Moment
 - AISC *Manual Part 11*
 - AISC *Manual Part 12*
 - DG4 – Extended End-Plate Moment Connections
 - DG16 – Flush & Extended Multiple-Row Moment End-Plate Connx




Connections

- Bracing
 - AISC *Manual Part 13*
 - DG29 – Vertical Bracing Connections-Analysis and Design
- Embedded Plates
- Post Installed Anchors
- Beam Pockets




Guard Post Connx

- Imparts torsion, shear, axial loads on stringer



Guard Post Connx

- Consider fit-up of post to stringer




Guard Post Connx

- Channel Stringer
 - Determine strength of channel flange

$$B_{eff} = N + 2(2.5) \left[\left(k - \frac{t_f}{2} \right) + b_f \right]$$


where
k = beam fillet dimension
t_f = flange thickness
b_f = flange width
N = guard post diameter

$$Z = \frac{B_{eff} t_w^2}{4} \quad S = \frac{B_{eff} t_w^2}{6}$$



Guard Post Connx

- Imparts torsion, shear, axial loads on stringer



Outline – Part 1

Step 1 – Purpose & Design Philosophy

Step 2 – Stairway Overview

Step 3 – Code Requirements - Gravity

Step 4 – Stairway Design

Step 5 – Members & Connx

Step 6 – Examples



111

Example 1: Opening Size


- Project requires:
 - Egress Stair for Office Building
 - Masonry Core Walls
 - Channel Stringers
 - Provide 6" clear gap between stringers



112




Example 1: Opening Size



Example Stair Layout



Example 1: Opening Size - Width



Example 1: Opening Size - Width

$$W_{\text{open}} = 2(\text{Edge Gap}) + 4(\text{Stringer Width}) + 2(\text{Egress Width}) + 1(\text{Center Gap})$$

- Edge Gap = 1/2"
- Stringer Width = 3" (C12x20.7)
- Egress Width = 44"
- Center Gap = 6"



115

Example 1: Opening Size - Width

$$W_{\text{open}} = 2(1/2") + 4(3") + 2(44") + 1(6")$$

$$W_{\text{open}} = 107" = \mathbf{8'-11"} \text{ clear dimension}$$



116



Example 1: Opening Size - Length

$$L_{\text{open}} = L_{\text{stair}} + L_{\text{landing}}$$

$$L_{\text{stair}} = N_{\text{tread}}(\text{Tread Length}) + (\text{Connection Allowance})$$

$$L_{\text{landing}} = N_{\text{landing}}[(\text{Stringer Width}) + (\text{Egress Width}) + (\text{End Gap})]$$



119

Example 1: Opening Size - Length

$$L_{\text{stair}} = N_{\text{tread}}(\text{Tread Length}) + (\text{Connection Allowance})$$

$$N = 10$$

$$\text{Tread Length} = 11''$$

$$\text{Allowance} = 6''$$



120



Example 1: Opening Size - Length

$$L_{\text{landing}} = N_{\text{landing}}[(\text{Stringer Width}) + (\text{Egress Width}) + (\text{End Gap})]$$

$$N = 1 \text{ landing}$$

$$\text{Stringer Width} = 3''$$

$$\text{Egress Width} = 44''$$

$$\text{End Gap} = 1/2''$$



121

Example 1: Opening Size - Length

$$L_{\text{open}} = L_{\text{stair}} + L_{\text{landing}}$$

$$L_{\text{stair}} = 10(11'') + (6'') = 116''$$

$$L_{\text{landing}} = 1[(3'') + (44'') + (1/2'')] = 47.5''$$


$$L_{\text{open}} = L_{\text{stair}} + L_{\text{landing}} = 116'' + 47.5'' = 163.5'' = \mathbf{13'-7 \frac{1}{2}''}$$



122


Example 1: Opening Size

Provide 8'-11" x 13'-7 1/2" Opening




Example 1: Opening Size

Provide 8'-11" x 13'-7 1/2" Opening



Example 2: Stringer Design

- Design low stringer
- 44" Wide Stair
- Span = 9'-8"
- Try C12x20.7
 - Fully braced by tread/riser
- $LC = D+L$ or $1.2D+1.6L$



125

Example 2: Stringer Design

- Imposed Loading

Dead Load:

Stringer Self weight

Guard Self weight

12 ga treads/risers with 2" concrete fill = 30 psf

Superimposed MEP loads = 5 psf

Total = 35 psf

Live Load:

Live load = 100 psf

Total = 100 psf



126



Example 2: Stringer Design

- Stringer Loads

Dead Load:

Stringer Self weight (20.7 lb/ft X 1.185 slope factor)	=	24.5	lb/ft
Guard Self weight (20 lb/ft)	=	20	lb/ft
12 ga treads/risers with 2" concrete fill = 30 psf X 1.84'	=	55.2	lb/ft
Superimposed MEP loads = 5 psf X 1.84'	=	9.2	lb/ft
Total	=	109	lb/ft


Live Load:

Live load = 100 psf X 1.84'	=	184	lb/ft
Total	=	184	lb/ft



127

Example 2: Stringer Design



$$R = V = \frac{wl}{2}$$

$$M_{\max} = \frac{wl^2}{8}$$

	ASD	LRFD
w	0.293 k/ft	0.425 k/ft
R	1.42 k	2.05 k
M	3.43 k-ft	4.97 k-ft



128



Example 2: Stringer Design

	ASD	LRFD
w	0.293 k/ft	0.425 k/ft
R	1.42 k	2.05 k
M	3.43 k-ft	4.97 k-ft

Refer to Manual Table 3-8

For C12x20.7, $L_b < L_p$

ASD

$$V_n/\Omega_v = 43.8 \text{ k} > 1.42 \text{ k OK}$$

$$M_p/\Omega_b = 46.0 \text{ k-ft} > 3.43 \text{ k-ft OK}$$

LRFD


$$\Phi_v V_n = 65.8 \text{ k} > 2.05 \text{ k OK}$$

$$\Phi_b M_p = 69.1 \text{ k-ft} > 4.97 \text{ k-ft OK}$$

C12x20.7 is adequate for imposed loads



Example 2: Stringer Design



Check Deflection:

$$\Delta = \frac{5 w \text{ kip/in.} (L \text{ in.})^4}{384 (29,000 \text{ ksi}) (I \text{ in.}^4)} = \frac{w \text{ kip/ft} (L \text{ ft})^4}{1,290 (I \text{ in.}^4)}$$

Live Load:

$$\Delta_{LL \text{ allowable}} = \frac{(9.67 \text{ ft}) \left(\frac{12 \text{ in.}}{1 \text{ ft}} \right)}{360} = 0.322 \text{ in.}$$

$$\Delta_{LL} = \frac{0.184 \text{ kip/ft} (9.67 \text{ ft})^4}{1,290 (129 \text{ in.}^4)} = 0.010 \text{ in.} < 0.322 \text{ in. OK}$$


Total Load:

$$\Delta_{TL \text{ allowable}} = \frac{(9.67 \text{ ft}) \left(\frac{12 \text{ in.}}{1 \text{ ft}} \right)}{240} = 0.484 \text{ in.}$$


$$\Delta_{TL} = \frac{0.293 \text{ kip/ft} (9.67 \text{ ft})^4}{1,290 (129 \text{ in.}^4)} = 0.015 \text{ in.} < 0.484 \text{ in. OK}$$




Example 3: Guard Post Connx



Example 3: Guard Post Connx



Example 3: Guard Post Connx




Guard Post
 ASTM A500 Gr. C Round
 $F_y = 46$ ksi
 $F_u = 62$ ksi

Channel
 ASTM A36
 $F_y = 36$ ksi
 $F_u = 58$ ksi



Example 3: Guard Post Connx




From AISC *Manual* Table 1-13, the
 geometric properties are as follows:
 ASTM A500 Gr. C HSS1.90x0.145
 Outside diameter = 1.90 in.

From AISC *Manual* Table 1-5, the
 geometric properties are as follows:
 ASTM A36 C12x20.7
 $k = 1.125$ in.
 $t_f = 0.501$ in.
 $b_f = 2.94$ in.
 $t_w = 0.282$ in.



Example 3: Guard Post Connx



$$M_{max} = PL$$

	ASD	LRFD
P	0.200 k	0.320 k
L	42"	
M	8.4 k-in	13.4 k-in



Example 3: Guard Post Connx

Determine effective width of channel top flange:


$$B_{eff} = N + 2(2.5) \left[\left(k - \frac{t_f}{2} \right) + b_f \right]$$

$$B_{eff} = 1.90 \text{ in.} + 2(2.5) \left[\left(1.125 \text{ in.} - \frac{0.501 \text{ in.}}{2} \right) + 2.94 \text{ in.} \right] = 20.97 \text{ in.}$$

Determine section modulus of effective web:

$$Z = \frac{B_{eff} t_w^2}{4} = \frac{20.97 \text{ in.} (0.282 \text{ in.})^2}{4} = 0.417 \text{ in.}^3$$

$$S = \frac{B_{eff} t_w^2}{6} = \frac{20.97 \text{ in.} (0.282 \text{ in.})^2}{6} = 0.278 \text{ in.}^3$$



Example 3: Guard Post Connx

Determine nominal flexural strength of C12 web:

$$\begin{aligned}M_p &= F_y Z \leq 1.6 M_y \\ &= F_y Z \leq 1.6 F_y S \\ &= 36 \text{ ksi} (0.417 \text{ in.}^3) \leq 1.6 (36 \text{ ksi}) (0.278 \text{ in.}^3) \\ &= 15.0 \text{ kip-in.} \leq 16.0 \text{ kip-in.} \\ &= 15.0 \text{ kip-in.}\end{aligned}$$

ASD

$$M_p / \Omega_b = 15.0 \text{ k-in} / 1.67$$

$$M_p / \Omega_b = 8.98 \text{ k-in} > 8.4 \text{ k-in OK}$$

LRFD

$$\Phi_b M_p = 0.9 (15.0 \text{ k-in})$$

$$\Phi_b M_p = 13.5 \text{ k-in} > 13.4 \text{ k-in OK}$$



137

Questions?



138

PDH Certificates

Within 2 business days...

- You will receive an email on how to report attendance from: registration@aisc.org.
 - Be on the lookout: Check your spam filter! Check your junk folder!
 - Completely fill out online form. Don't forget to check the boxes next to each attendee's name!
-



PDH Certificates

Within 2 business days...

- Reporting site (URL will be provided in the forthcoming email).
 - Username: Same as AISC website username.
 - Password: Same as AISC website password.
-



There's always a solution in steel.

Thank You

Please give us your feedback!
Survey at conclusion of webinar.

