

---

**Supplement No. 1 to the  
Specification for the Design, Fabrication,  
and Erection of Steel Safety-Related  
Structures for Nuclear Facilities**  
(ANSI/AISC N690-1994)

---

Approved by the  
AISC Committee on Specifications and  
issued by the AISC Board of Directors  
**April 15, 2002**



Copyright © 2002

by

American Institute of Steel Construction, Inc.

*All rights reserved. This book or any part thereof must not be reproduced in any form without the written permission of the publisher.*

*The AISC logo is a registered trademark of AISC and is used under license.*

The information presented in this publication has been prepared in accordance with recognized engineering principles and is for general information only. While it is believed to be accurate, this information should not be used or relied upon for any specific application without competent professional examination and verification of its accuracy, suitability, and applicability by a licensed engineer, architect or other professional. The publication of the material contained herein is not intended as a representation or warranty on the part of the American Institute of Steel Construction, Inc. or of any other person named herein, that this information is suitable for any general or particular use or of freedom from infringement of any patent or patents. Anyone making use of this information assumes all liability arising from such use.

Caution must be exercised when relying upon other specifications and codes developed by other bodies and incorporated by reference herein since such material may be modified or amended from time to time subsequent to the printing of this edition. The American Institute of Steel Construction, Inc. bears no responsibility for such material other than to refer to it and incorporate it by reference at the time of the initial publication of this edition.

**Supplement No. 1 to the Specification  
for the Design, Fabrication, and Erection  
of Steel Safety-Related Structures  
for Nuclear Facilities  
(ANSI/AISC N690-1994)**

April 15, 2002

**Page 1**

**Q1.0.1 SCOPE**

Revise Item 5 as follows:

5. A quality assurance program covering nuclear safety-related steel structures shall be developed prior to starting any work. The general requirements and guidelines for establishing and executing the quality assurance program during the design and construction phases of nuclear facilities are those established by Title 10 of the Code of Federal Regulations, Part 50 (10CFR50) Appendix B for Nuclear Power Stations and Independent Spent Fuel for Commercial Reactors Storage Facilities or Part 830.120 (10CFR830.120) for applicable U.S. Department of Energy Nuclear Facilities.

Add the following to the end of this section:

This Specification includes the list of symbols and the appendices.

Single angle members shall comply with the *Specification for Allowable Stress Design of Single-Angle Members* and with this Specification.

Design of structural joints shall comply with the *Specification for Structural Joints Using ASTM A325 or A490 Bolts* (Research Council on Structural Connections) and the *Structural Welding Code-Steel* (AWS D1.1), and with this specification.

**Page 2**

**Q1.0.2 DEFINITIONS**

Replace the definition for Secondary Stress with the following:

**Secondary Stress**

Secondary stress is a stress developed by the self-constraint of a structure rather than from external loads. It must satisfy an imposed strain pattern. The basic characteristic of a secondary stress is that it is self-limiting. Examples of secondary stresses are effects arising from contraction or expansion resulting from one or more of the following:

- Temperature changes
- Shrinkage, moisture changes, creep in concrete for composite construction
- Movement due to differential settlement
- Variation from the assumed connection restraint

Page 3

### Q1.0.3 REFERENCED CODES AND STANDARDS

Replace this section with the following:

The following documents are referenced in this Specification. Whenever referenced, the documents by date of issue indicated in this section apply.

ASTM A6/A6M-01	ASTM A20/A20M-01
ASTM A27/A27M-95(2000)	ASTM A36/A36M-00
ASTM A53/A53M-01	ASTM A106-99e1
ASTM A148/A148M-01	ASTM A167-99
ASTM A193/A193M-01	ASTM A194/A194M-01
ASTM A216/A216M-93(1998)	ASTM A217/A217M-99
ASTM A240/A240M-01	ASTM A242/A242M-00a
ASTM A276-00a	ASTM A307-00
ASTM A312/A312M-00c	ASTM A320/A320M-01
ASTM A325-00	ASTM A354-00a
ASTM A449-00	ASTM A479/A479M-00
ASTM A490-00	ASTM A500-01
ASTM A501-01	ASTM A514/A514M-00a
ASTM A515/A515M-92(1997)	ASTM A516/A516M-90(2001)
ASTM A529/A529M-01	ASTM A540/A540M-00
ASTM A563-00	ASTM A564/A564M-01
ASTM A568/A568M-00b	ASTM A572/A572M-00a
ASTM A588/A588M-00a	ASTM A606-01
ASTM A607-98	ASTM A618-01
ASTM A668/A668M-96e1	ASTM A709/A709M-01b
ASTM A852/A852M-01	ASTM A913/A913M-01
ASTM A992/A992M-01	ASTM A1011-01
ASTM C33-01	ASTM D3843-00
ASTM F436-93(2000)	ASTM F436M-93(2000)
ASTM F1554-99	

American Concrete Institute, *Standard Code Requirements for Nuclear Safety-Related Concrete Structures*, ACI 349-01.

AISC *Specification for Allowable Stress Design of Single-Angle Members*, June 1, 1989.

AISC *Specification for Structural Steel Buildings – Allowable Stress Design and Plastic Design*, June 1, 1989.

AISC *Load and Resistance Factor Design Specification for Structural Steel Buildings*, December 27, 1999.

AISC *Code of Standard Practice for Steel Buildings and Bridges*, March 7, 2000.

ASME *Boiler and Pressure Vessel Code*, Section IX, QW-214, 2001.

American Welding Society, *Structural Welding Code – Steel*, D1.1:2000.

American Society of Civil Engineers, *Minimum Design Loads for Buildings and Other Structures*, ASCE 7-98.

ANSI/ASME NQA-1: *Quality Assurance Program Requirements for Nuclear Facilities*, 1992.

Research Council on Structural Connections, *Specification for Structural Joints Using ASTM A325 or A490 Bolts*, 2000.

Title 10 of the *Code of Federal Regulation*, Part 50, Appendix B, 2001.

Title 10 of the *Code of Federal Regulation*, Part 830.120 (to be used for Department of Energy Nuclear Facilities), 2001.

U.S. Nuclear Regulatory Commission Regulatory Guide 1.54, "Service Level I, II, and III Protective Coatings Applied to Nuclear Power Plants," July 2000.

*Visual Weld Acceptance Criteria for Structural Welding at Nuclear Power Plants* (NCIG-01, Revision 2), Electric Power Research Institute, NP-5380, Volume 1, September 1987.

**Page 7**

### **Q1.3.6 LOAD COMBINATIONS**

Add the following to this section:

When any load reduces the effects of other loads and if it can be demonstrated that the load is always present or occurs simultaneously with other loads, the corresponding coefficient for that load shall be taken as 0.90. Otherwise, the coefficient for that load shall be taken as zero.

**Page 7**

Insert the following new Section Q1.3.7:

**Q1.3.7 COMBINED LOSS OF COOLANT AND SAFETY RELIEF DISCHARGE LOADS**

In addition to the abnormal loads identified in Q1.3.5, hydrodynamic loads resulting from LOCA and/or safety relief valve actuation shall be appropriately considered for steel structure components subjected to these loads. Any fluid structure interaction associated with these hydrodynamic loads and those from the postulated seismic loads shall be taken into account.

**Page 8**

**Q1.4.1 STRUCTURAL STEEL**

Add the following standard specifications:

ASTM A529/A529M	<i>High-Strength Carbon-Manganese Steel of Structural Quality</i>
ASTM A606	<i>Steel, Sheet and Strip, High-Strength, Low-Alloy, Hot-Rolled and Cold-Rolled, with Improved Atmospheric Corrosion Resistance</i>
ASTM A709/A709M	<i>Structural Steel for Bridges</i>
ASTM A852/A852M	<i>Quenched and Tempered Low-Alloy Structural Steel Plate with 70 ksi Minimum Yield Strength to 4-in. Thick</i>
ASTM A913/A913M	<i>High-Strength Low-Alloy Steel Shapes of Structural Quality, Produced by Quenching and Self-Tempering Process (QST)</i>
ASTM A992/A992M	<i>Steel for Structural Shapes for Use in Building Framing</i>

**Page 8**

**Q1.4.1 STRUCTURAL STEEL**

Add the following to the end of this section:

Some of the material classes and types listed in ASTM standards A167, A276, and A607 are not generally suitable for use in welded applications.

Therefore, A167 Types 301, 302, 302B, and 305; A276; and A607 Class 1 shall not be used in welded applications.

**Page 10**

**Q1.4.3 BOLTS AND MATERIAL FOR THREADED RODS**

Add the following standard specifications:

ASTM A36/A36M	<i>Carbon Structural Steel</i>
ASTM A588/A588M	<i>High-Strength Low-Alloy Structural Steel with 50 ksi [345MPa] Minimum Yield Point to 4-in. [100 mm] Thick</i>
ASTM A193/A193M	<i>Alloy Steel and Stainless Steel Bolting Materials for High-Temperature Service</i>
ASTM A194/A194M	<i>Carbon and Alloy Steel Nuts for Bolts for High-Pressure or High-Temperature Service, or Both</i>
ASTM F436	<i>Hardened Steel Washers</i>
ASTM F436M	<i>Hardened Steel Washers [Metric]</i>
ASTM F1554	<i>Anchor Bolts, Steel, 36, 55, and 105-ksi Yield Strength</i>

**Page 11**

**Q1.4.4 FILLER METAL AND FLUX FOR WELDING**

Add the following specifications of the American Welding Society:

AWS A5.23	<i>Specification for Low-Alloy Steel Electrodes and Fluxes for Submerged Arc Welding</i>
AWS A5.28	<i>Specification for Low-Alloy Filler Metals for Gas Shielded Arc Welding</i>
AWS A5.29	<i>Specification for Low-Alloy Steel Electrodes for Flux Cored Arc Welding</i>

Add the following to the end of this section:

For Charpy V-notch testing requirements, see Section Q1.17.1.

**Page 18**

**Table Q1.5.2.1**

Insert the following at the bottom of the table:

A490 bolts, when threads are excluded from shear planes 54.0<sup>d</sup> 21.0 18.0 15.0 13.0 40.0<sup>f</sup>

## Q1.5.5 CONCRETE BEARING

Revise the definition of  $A_1$  and  $A_2$  as follows:

- $A_1$  = area of steel concentrically bearing on a concrete support, in.<sup>2</sup>  
 $A_2$  = maximum area of the portion of the supporting surface that is geometrically similar to and concentric with the loaded area, in.<sup>2</sup>

## Table Q1.5.7.1

Insert revised Table.

**TABLE Q1.5.7.1**  
**Load Combinations and Applicable Stress Limit Coefficients**

Category	Load Combination <sup>l</sup>	Stress Limit Coefficient <sup>b,h</sup>
Normal	1. $D + L$	1.0 <sup>c</sup>
	2. $D + L + R_o + T_o$	
Severe <sup>i</sup>	3. $D + L + W$	1.0 <sup>c</sup>
	4. $D + L + E_o$	
	5. $D + L + W + R_o + T_o$	
	6. $D + L + R_o + T_o + E_o$	
Extreme	7. $D + L + R_o + T_o + W_t$	1.6 <sup>g,k</sup>
	8. $D + L + R_o + T_o + E_s$	
Abnormal <sup>d</sup>	9. $D + L + R_a + T_a + P_a$	1.6 <sup>g,k</sup>
Abnormal <sup>d,i</sup>	9a. $D + L + T_a + P_a$	
Abnormal <sup>d,g</sup> Severe	10. $D + L + R_a + T_a + Y_r + Y_j + Y_m + E_o + P_a$	1.6 <sup>g,k</sup>
Abnormal <sup>d,g</sup> Extreme	11. $D + L + R_a + T_a + Y_r + Y_j + Y_m + E_s + P_a$	1.7 <sup>g,k</sup>

<sup>a</sup> Coefficients are applicable to primary stress limits given in Sections Q1.5.1, Q1.5.2, Q1.5.3, Q1.5.4, Q1.5.5, Q1.6, Q1.10, and Q1.11.

<sup>b</sup> In no instance shall the allowable stress exceed  $0.7F_u$  in axial tension nor  $0.7F_u$  times the ratio  $Z/S$  for tension plus bending.

<sup>c</sup> For primary plus secondary stress, the allowable limits are increased by a factor of 1.5.

<sup>d</sup> The maximum values of  $P_a$ ,  $T_a$ ,  $R_a$ ,  $Y_j$ ,  $Y_r$ , and  $Y_m$ , including an appropriate dynamic load factor, shall be used in load combinations 9 through 11, unless an appropriate time history analysis is performed to justify otherwise.

<sup>e</sup> In combining loads from a loss of coolant accident (LOCA) and a seismic event the SRSS (square root of the sum of the squares) may be used, provided that the responses are calculated on a linear basis.

<sup>f</sup> All load combinations shall be checked for a no-live-load condition.

<sup>g</sup> In load combinations 7 through 11, the stress limit coefficient in shear shall not exceed 1.4 in members and bolts.

<sup>h</sup> Secondary stresses which are used to limit primary stresses shall be treated as primary stresses.

<sup>i</sup> Consideration shall also be given to snow and other loads as defined in ASCE 7.

<sup>j</sup> This load combination is to be used when the global (non-transient) sustained effects of  $T_a$  are considered.

<sup>k</sup> The stress limit coefficient where axial compression exceeds 20% of normal allowable, shall be 1.5 for load combinations 7, 8, 9, 9a, and 10 and 1.6 for load combination 11.

## Page 22

**Q1.5.8 DESIGN BASED ON DUCTILITY AND LOCAL EFFECTS**

In subparagraph a, delete  $T_a$  from the list of load effects.

## Page 23

**Table Q1.5.8.1**

In the title, replace "EXTREME AND ABNORMAL LOADS" with "IMPACTIVE AND IMPULSIVE LOADS".

Add footnote "\*\*\*" to Paragraph 3 heading.

## Page 24

**Q1.5.9.1 COMPRESSION**

Revise Eqn. Q1.5-12 to the following:

$$F_a = F_y \left[ 0.40 - \frac{1}{600} \frac{Kl}{r} \right]$$

## Page 26

Revise the last line to read:

$T_b$  = specified pretension load in the bolt (see Table Q1.6.3.1), kips

## Page 27

Add the following Table Q1.6.3.1 to this page.

**TABLE Q1.6.3.1**  
**Minimum Bolt Pretension, kips\***

Bolt Size, in.	A325 Bolts	A490 Bolts
1/2	12	15
5/8	19	24
3/4	28	35
7/8	39	49
1	51	64
1 1/8	56	80
1 1/4	71	102
1 3/8	85	121
1 1/2	103	148

\* Equal to 0.70 of minimum tensile strength of bolts, rounded off to nearest kip, as specified in ASTM specifications for A325 and A490 bolts with UNC threads.

Page 28

**Q1.6.3 SHEAR AND TENSION FOR BOLTS**

Revise the definition for  $K_s$ , as follows in sub-section 3a:

$K_s$  = slip coefficient for the particular surface conditions taken from Table Q1.6.3.2.

Page 28

**Table Q1.6.3 Slip Coefficient,  $K_s$** 

Change this table heading to Table Q1.6.3.2.

Page 31

**Q1.10.1 PROPORTIONS**

Add the following sentence to the end of this section:

No limit is placed on the web stresses produced by the applied bending moment for which a hybrid girder is designed, except as provided in Sect. Q1.7 and Appendix QB.

Page 39

**Q1.11.2.2 NON-ENCASED BEAMS USING SHEAR CONNECTORS**

Delete the first paragraph on page 39.

Page 43

**Q1.13.2 PONDING**

Revise the definitions in this section as follows:

$S$  = spacing of secondary members, ft  
 $I_p$  = moment of inertia of primary members, in.<sup>4</sup>  
 $I_s$  = moment of inertia of secondary members, in.<sup>4</sup>  
 $I_d$  = moment of inertia of the steel deck supported on secondary members, in.<sup>4</sup> per ft

Add the following sentence to the 3<sup>rd</sup> paragraph of this section:

A steel deck shall be considered a secondary member when it is directly supported by the primary members.

Page 44

**Q1.14.2.2 SHEAR LAG**

In the 2<sup>nd</sup> paragraph, first line, delete "or rivets".

In subparagraph a., 2<sup>nd</sup> and 3<sup>rd</sup> line, delete "or riveted".

In subparagraph b., 3<sup>rd</sup> line, delete "or riveted".

In subparagraph c., 1<sup>st</sup> line, delete "or riveted".

#### **Page 49**

#### **Q1.15.11 FIELD CONNECTIONS**

Change the heading of this section to "Limitations on Bolted and Welded Connections".

Replace entire section with the following:

Pretensioned high-strength bolts (see Table Q1.6.3.1) or welds shall be used for the following connections:

All column splices

Connections of all beams and girders to columns and of any other beams and girders on which the bracing of columns is dependent

Roof truss splices and connections of trusses to columns, column splices, column bracing, knee braces, and crane supports

Connections for supports of running machinery or of other live loads which produce impact or reversal of stress

Any other connections stipulated on the design plans.

In all other cases, connections shall be permitted to be made with high-strength bolts tightened to the snug-tight condition or with A307 bolts.

#### **Page 50**

#### **Q1.16.1 HIGH-STRENGTH BOLTS**

Replace the second and third line in the second paragraph with the following:

A449 bolts in tension and bearing-type shear connections shall have an ASTM F436 hardened washer installed under the bolt head, and the nuts shall meet the requirements of ASTM A563.

#### **Page 50**

#### **Q1.16.2 EFFECTIVE BEARING AREA**

Add the following sentence to this section:

For allowable bearing at bolt holes, see Sect. Q1.5.1.5.3.

#### **Page 51**

#### **Q1.16.4.2 SPACING ALONG LINE OF FORCE**

Replace the second line of the first paragraph with:

$F_p$  is determined by Formulas (Q1.5-7) and (Q1.5-8). Otherwise, the distance between centers of holes shall not be less....

**Page 51**

**Q1.16.5.2 SPACING ALONG LINE OF FORCE**

Change heading of Section Q1.16.5.2 to EDGE DISTANCE ALONG THE LINE OF FORCE.

Replace the first paragraph with the following:

Along a line of transmitted force, in the direction of the force, the distance from the center of a standard hole to the edge of the connected part shall be not less than  $1\frac{1}{2}d$  when  $F_p$  is determined from Formulas (Q1.5-7) and (Q1.5-8). Otherwise the edge distance shall not be less than:

**Page 53**

**Q1.17.1 GENERAL**

Replace the entire section with the following:

All provisions of AWS D1.1 apply under this specification, except the provisions applicable to Tubular Structures, which are outside the scope of this specification, and except that the provisions of the listed ANSI/AISC N690-1994 Specification Sections apply under this Specification in lieu of the cited AWS Code provisions as follows:

AISC Specification Section Q1.15.12 and Q1.15.13 in lieu of AWS D1.1 Section 5.17

AISC Specification Section Q1.14.6 in lieu of AWS D1.1 Section 2.4.1.1

AISC Specification Table Q1.5.3 in lieu of AWS D1.1 Table 2.3

AISC Specification Table QB-2 of Appendix QB in lieu of AWS D1.1 Section 2.27.1

AISC Specification Section Q1.7 and Appendix QB in lieu of AWS Section 2, Part C

AISC Specification Section Q1.23.3.1 and Q1.23.3.2 in lieu of AWS Sections 5.15.1.2, 5.15.4.3 and 5.15.4.4

The length and disposition of welds, including end returns shall be indicated on the design and shop drawings.

The choice of filler metal for use with complete-joint-penetration groove welds subject to tension normal to the effective area shall comply with the requirements for matching weld metals given in AWS D1.1.

Filler metal to be used in the following joints shall be capable of depositing weld metal with a specified Charpy V-notch (CVN) toughness of 20 ft-lbs at 40°F.

- (a) Complete-joint-penetration groove welded T and corner joints with steel backing left in place, subject to tension normal to the effective area, unless the joints are designed with the allowable stress for partial penetration welds per Table Q1.5.3.
- (b) Complete-joint-penetration groove welded splices subject to tension normal to the effective area in Group 4 and Group 5 shapes and shapes built up by welding plates more than two in. thick.

**Page 57**

#### **Q1.18.3.1 COMPONENTS IN CONTACT**

Replace this section with the following:

The longitudinal spacing of connectors between elements in continuous contact consisting of a plate and a shape or two plates shall not exceed:

24 times the thickness of the thinner plate, nor 12 in. for painted members or unpainted members not subject to corrosion.

14 times the thickness of the thinner plate, nor 7 in. for unpainted members of weathering steel subject to atmospheric corrosion.

In a tension member the longitudinal spacing of fasteners and intermittent welds connecting two or more shapes in contact shall not exceed 24 inches. Tension members composed of two or more shapes or plates separated by intermittent fillers shall be connected to one another at these fillers at intervals such that the slenderness ratio of either component between the fasteners does not exceed 300.

**Page 57**

#### **Q1.18.3.2 PERFORATED COVER PLATES**

Replace the last sentence of this section with the following:

The spacing of tie plates shall be such that the slenderness ratio of any component in the length between tie plates does not exceed 300.

**Page 60**

#### **Q1.23.3.1 THERMAL CUTTING**

Delete the existing paragraph and replace with the following:

Thermally cut edges shall meet the requirements of AWS D1.1, Sections 5.15.1.2, 5.15.4.3 and 5.15.4.4 with the exception that thermally cut free edges which will be subject to calculated static tensile stress shall be free of round bottom gouges greater than 3/16-in. deep and sharp V-shaped notches. Gouges greater than 3/16-in. up to 3/8-in. deep and notches shall be removed by grinding at a slope of 1 to 2 1/2 or repaired by welding. Unrepaired notches and gouges should not result in a weld gap that exceeds the maximum allowed by AWS D1.1. Notches or gouges 3/8-in. deep or greater shall be permitted to be repaired only with the approval of the engineer. Oxygen gouging shall be prohibited on quenched and tempered steels.

Page 61

#### Q1.23.7.2 LIMITATIONS ON PUNCHED HOLES

Add the following to the end of the first paragraph of this Section:

Finger shims up to 1/4 in. shall be permitted to be introduced into slip-critical connections designed on the basis of standard holes without reducing the allowable shear stress of the fastener.

Page 62

#### Table Q1.23.7 Maximum Sizes of Fastener Holes, Inches

Change the heading to "Nominal Hole Dimensions" and replace the existing Table Q1.23.7 with the following table:

**TABLE Q1.23.7**  
**Nominal Hole Dimensions**

Bolt Diameter	Hole Dimensions			
	Standard (Dia.)	Oversize (Dia.)	Short-slot (Width x length)	Long-slot (Width x length)
1/2	9/16	5/8	9/16 × 11/16	9/16 × 1 1/4
5/8	11/16	13/16	11/16 × 7/8	11/16 × 1 9/16
3/4	13/16	15/16	13/16 × 1	13/16 × 1 7/8
7/8	15/16	1 1/16	15/16 × 1 1/8	15/16 × 2 3/16
1	1 1/16	1 1/4	1 1/16 × 1 5/16	1 1/16 × 2 1/2
≥ 1 1/8	$d + 1/16$	$d + 5/16$	$(d + 1/16) \times (d + 3/8)$	$(d + 1/16) \times (2.5 \times d)$

**Page 62****Q1.23.8 HIGH-STRENGTH BOLTED CONSTRUCTION – ASSEMBLING**

Add the following paragraph after the existing first paragraph of this section:

If the thickness of the material is not greater than the nominal diameter of the bolt plus  $\frac{1}{8}$  in., the holes shall be permitted to be punched. If the thickness of the material is greater than the nominal diameter of the bolt plus  $\frac{1}{8}$  in., the holes shall be either drilled or sub-punched and reamed. The die for all sub-punched holes and the drill for all sub-drilled holes shall be at least  $\frac{1}{16}$  in. smaller than the nominal diameter of the bolt. Holes in A514 steel plates over  $\frac{1}{2}$ -in. thick shall be drilled.

**Page 64****Q1.24 SHOP PAINTING**

Delete the current wording and replace with the following:

**Q1.24.1 GENERAL REQUIREMENTS**

Shop painting and surface preparation shall be in accordance with the provisions of the *Code of Standard Practice* of the American Institute of Steel Construction, Inc.

Unless otherwise specified, steelwork that will be concealed by interior building finish or will be in contact with concrete need not be painted. Unless specifically excluded, all other steelwork shall be given one coat of shop paint.

The quality assurance requirements for painting (or coating) of structural steel shall be in accordance with ASTM D3843 as endorsed by Regulatory Guide 1.54.

**Q1.24.2 INACCESSIBLE SURFACES**

Except for contact surfaces, surfaces inaccessible after shop assembly shall be cleaned and painted prior to assembly, if required by the design documents.

**Q1.24.3 CONTACT SURFACES**

Paint is permitted unconditionally in bearing-type connections. For slip-critical connections, the faying surface requirements shall be in accordance with the RCSC *Specification for Structural Joints Using ASTM A325 or A490 Bolts*, paragraph 3.2.2.

**Q1.24.4 FINISHED SURFACES**

Machine-finished surfaces shall be protected against corrosion by a rust-inhibiting coating that can be removed prior to erection, or which has characteristics that make removal prior to erection unnecessary.

**Q1.24.5 SURFACES ADJACENT TO FIELD WELDS**

Unless otherwise specified in the design documents, surfaces within 2 in. of any field weld location shall be free of materials that would prevent proper welding or produce toxic fumes during welding.

Page 66

**Q1.25.10 FIELD PAINTING**

Replace current text with the following:

Responsibility for touch-up painting, cleaning and field-painting shall be allocated in accordance with accepted local practices, and this allocation shall be set forth explicitly in the design documents.

Page 67

**Q1.28 PACKAGING, SHIPPING, RECEIVING, STORAGE**

Replace the sentence with:

Packaging, shipping, receiving, storage, and handling shall be in accordance with ASME NQA-1, Supplement 13S-1.

Page 67

**Q1.29 QUALITY CONTROL**

Add new Section Q1.29 as follows:

The fabricator shall provide control procedures to the extent deemed necessary to assure that all work is performed in accordance with this Specification. In addition to the fabricator's quality control procedures, material and workmanship at all times may be subject to inspection by qualified inspectors representing the purchaser. If such inspection by representatives of the purchaser will be required, it shall be so stated in design documents.

**COMMENTARY****Page C-1**

Add new Section CQ1.0.1.

## CQ1.0.1 SCOPE

The following commentary pertains to Item 5:

DOE Standard 1021 (Department of Energy, 1996) has established Performance Categories and target probabilistic performance goals for each category of facility subjected to natural hazards phenomena (NPA). Performance goals in the context of the DOE standard are expressed as the mean annual probability of exceedance of acceptable behavior limits of structures and equipment due to the effects of natural phenomena. Such performance goals should not be confused with broader safety goals associated with the undefined release of radioactivity to the public (Performance Categories 2 and 3) which are typically one or two orders of magnitude less than the structural failure performance goals presented herein. Five Performance Categories (PC) have been established which range from PC-0 to PC-4 as shown in Table CQ1.0.1. Performance Categories and performance goals range from those for conventional buildings to those for facilities with storage or processing of high hazard materials.

The design and evaluation criteria for structures, systems and components (SSCs) in Performance Categories 0, 1, and 2 are similar to those given in model building codes. Performance Category 0 recognized that for certain lightweight equipment items, etc., and for other special circumstances where there is little or no potential impact on life safety, mission, or cost, design or evaluation for natural phenomena hazards may not be needed. Assignment of an SSC to Performance Category 0 is intended to be consistent with model building code NPH provisions. Performance Category 1 applies to ordinary structures, systems and components and Category 2 applies to essential or hazardous structures, systems and components, as defined in national building codes.

Performance Categories 3 and 4 apply to the facilities which pose a potential significant hazard to public safety and the environment because radioactive or toxic materials are present in significant quantities. Design objectives for these categories are to limit SSC damage so that these hazardous materials can be controlled, contained or confined, occupants are protected, and functioning of the SSC is not interrupted. The performance goal for Performance Category 3 and 4 SSCs is to limit damage such that DOE policy safety goals are achieved. For these categories, damage must typically be limited such that these hazardous materials are kept within containment or confinement barriers (e.g. buildings, storage canisters, vaults, etc.), ventilation systems and filtering, and monitoring and control equipment perform their safety function in the event of Design Basis Hazards. In addition, SSCs can be placed in Performance Categories 3 or 4 if improved performance is needed due to cost of recovery or mission requirements.

**TABLE CQ1.0.1**  
**Structure, System, or Component (SSC) NPH**  
**Performance Goals for Various Performance Categories**

Performance Category	Performance Goal Description	NPH Performance Goal Annual Probability of Exceeding Acceptable Structural Behavior Limits, $P_F^{(1,2,3)}$
0	No Safety, Mission, or Cost Considerations	No Requirements
1	Maintain Occupant Safety	$\approx 10^{-3}$ of the onset of SSC <sup>(1)</sup> damage to the extent that occupants are endangered
2	Occupant Safety, Continued Operation with Minimum Interruption	$\approx 5 \times 10^{-4}$ of SSC damage to the extent that the component cannot perform its function
3	Occupant Safety, Continued Operation, Hazard Confinement	$\approx 10^{-4}$ for SSC damage to the extent that the component cannot perform its function
4	Occupant Safety, Continued Operation, Confidence of hazard Confinement	$\approx 10^{-5}$ of SSC damage to the extent that the component cannot perform its function
(1) These performance goals are for each natural phenomenon hazard (earthquake, wind, and flood). (2) SSC refers to structure, distribution system, or component (equipment). (3) These Performance Goals should not be confused with undefined radiological risks to the public safety goals, which are typically set one to two orders of magnitude less than these risk levels.		

Page C-1

### CQ1.0.2 DEFINITIONS

Add the following new commentary.

It is appropriate to allow higher allowable stresses when the effects of conservatively estimated differential settlement are considered in the design, though it is recognized that the stresses induced are not self limiting. However, in the design of nuclear facilities, effects of differential settlement on the supported equipment and piping should also be explicitly considered.

**Page C-1****CQ1.0.3 REFERENCED CODES AND STANDARDS**

Add the following new commentary.

This Supplement No. 1 updates the applicable year of revision for the various Standards of the American Society for Testing and Materials (ASTM), and other referenced Codes and Standards, which were identified in N690-1994. Later editions of these Codes and Standards should be permitted to be used provided the Engineer performs a reconciliation.

ANSI 101.4 was withdrawn in 1988, and a number of ASTM Standards related to coatings were developed. The revised U.S. Nuclear Regulatory Commission Regulatory Guide 1.54 provides guidance in the use of these ASTM Standards for coatings to be used in the nuclear power plants.

**Page C-2****CQ1.3.6 LOAD COMBINATIONS**

Delete the last sentence in the first paragraph and add the following new paragraph:

Dynamic loads are typically determined based on time history analysis or response spectrum modal analysis. Procedures for combining seismic dynamic load effects so determined can be found in ASCE 4 (ASCE, 1998b) for structures and ASME BPVC Section III, Appendix N for mechanical components and distribution systems. Procedures for determining wind and snow load effects can be found in ASCE 7 (ASCE, 1998a).

Insert the following at the end of this section:

For ASD, ASCE 7 (ASCE, 1998a) requires that when combining with lateral loads, the dead load shall be reduced to 60 percent of the calculated dead load. For commercial buildings, ASCE may have found it appropriate to reduce the (dead) load factor to 0.6 in conjunction with lateral loads. For nuclear structures, it will be overly conservative. When the permanent equipment loads are considered as part of the dead load, NUREG/CR 3315, "A Consensus Estimation Study of Nuclear Power Plant Structural Loads," indicates that the mean values of dead loads for all types of reactors varies between 0.9 and 1.0 with a COV of 0.03. Thus, for nuclear plant design, the dead load factor remains unchanged.

This specification also takes exception to the load combination for dead load combined with lateral loads, given in the RCSC Specification.

**Page C-2**

Add the following new commentary section.

### **CQ1.3.7 COMBINED LOSS OF COOLANT AND SAFETY DISCHARGE LOADS**

The Nuclear Regulatory Commission's Standard Review Plan (SRP) Section 3.8.1, Appendix A, and SRP 3.8.3 provide guidance for incorporating the hydrodynamic loads.

#### **Page C-18**

### **CQ1.5.8 DESIGN BASED ON DUCTILITY AND LOCAL EFFECTS**

Add the following to the beginning of this section.

Load  $T_a$  acting alone is deleted from this section as the temperature effects are sustained compared to  $R_a$ ,  $Y_j$ , etc., and its effects are considered in load combination 9a. However, the global effects of  $T_a$  should be considered (as applicable) in conjunction with the impactive and impulsive loads as required by load combinations 9, 10, and 11.

#### **Page C-50**

### **CQ1.18 BUILT-UP MEMBERS**

Add the following to the first paragraph:

The slenderness ratio  $L/r$  of tension members other than rods, HSS, or straps should preferably not exceed the limiting value of 300. This slenderness limit recommended for tension members is not essential to the structural integrity of such members; it merely assures a degree of stiffness such that undesirable lateral movement ("slapping" or vibration) will be unlikely.

#### **Page C-52**

Add the following new commentary.

### **CQ1.29 QUALITY ASSURANCE**

The Nuclear Regulatory Commission has accepted the use of ANSI/ASME NQA-1, "Quality Assurance Requirements for Nuclear Facilities", 1986 Edition through 1992 Edition provided the owners of nuclear facilities utilize their 10 CFR 50, Appendix B quality assurance program in conjunction with the quality assurance and quality control requirements of this Standard.

Add the following references:

American Society of Mechanical Engineers (ASME) (1992), *Quality Assurance Program Requirements for Nuclear Facilities*, ANSI/ASME NQA-1, New York, NY.

American Society of Civil Engineers (ASCE) (1998a), *Minimum Design Loads for Buildings and Other Structures*, ASCE 7, Reston, VA.

American Society of Civil Engineers (ASCE) (1998b), *Seismic Analysis of Safety-Related Nuclear Structures*, ASCE 4, Reston, VA.

Department of Energy (1996), "Natural Phenomena Hazards Performance Categorization Criteria for Structures, Systems and Components," January, DOE-STD-1021-93, Ch. 1.







**American Institute of Steel Construction, Inc.**  
One East Wacker Drive, Suite 3100, Chicago, IL 60601-2000

(8/02:5M:SR)